

13 July 2016

Hon Bryan Green MP  
Labor Leader  
Tasmania

By Email [gordon.luckman@parliament.tas.gov.au](mailto:gordon.luckman@parliament.tas.gov.au)

Dear Mr Green,

### **Right to Information Request - 9 June 2016**

I refer to your request pursuant to the *Right to Information Act 2009* (RTI Act) received on 9 June 2016 by Hydro Tasmania.

I am authorised to make decisions on behalf of Hydro Tasmania in respect of applications for information under the RTI Act.

#### **1. Your Request**

Your original request was:

“The service history, infrastructure upgrades and maintenance logs of Hydro power stations from 1<sup>st</sup> January 2013 to 9<sup>th</sup> June 2016.”

It was subsequently agreed to change the scope of the request to “the provision of a schedule of key and major works to hydro power stations and other related infrastructure from 1 January 2013 to 9 June 2016” - hereinafter referred to as ‘the Request’.

#### **2. Determination and Reasons for Determination of the Request**

In determining the information relevant to the Request I refer to the telephone conversation with Mr Luckman of your office on 4 July.

In the discussion I advised that if agreement could not be reached to change the scope of the Request, it would be determined to refuse to provide the information in accordance with Section 19 of the RTI Act. It was estimated that there were in excess of 300,000 pieces of information which may be relevant to the request and that identifying and collating the information would substantially and unreasonably divert the resources of the Corporation from its other work.

Mr Luckman understood and agreed to the provision of a schedule of the key and major works undertaken on the hydro power stations and related infrastructure items over the Request period. It was also agreed that the release of this information would be delayed until the date of this reply.

Therefore, the information contained in the attached spreadsheet marked ‘A’ of 2 pages has been determined as relevant to the agreed change of scope of the Request.

#### **3. Information withheld**

In accordance with the amended scope there was no information withheld relevant to the Request.


A copy of this determination will be placed on the Hydro Tasmania website for public information.

#### **4. Review Rights**

As all information relevant to the Request (as amended) has been provided there is no review process for the determination.

This request is now considered closed.

Yours sincerely

A handwritten signature in black ink, appearing to read 'Alan W. Evans', enclosed in a thin black rectangular border. The signature is stylized with a large, sweeping initial 'A'.

Alan W. Evans  
Right to Information Officer & Corporation Secretary  
Hydro Tasmania  
t 03 6230 5300  
e [alan.evans@hydro.com.au](mailto:alan.evans@hydro.com.au)  
f 03 6231 4217

A

	Asset	Asset Description	Title	Planned Start	Planned End
100000103	TU2	Machine 2; Tungatinah Power Station	Major Machine Refurbishment	8/01/2013 8:15	4/04/2014 13:00
100000128	PL1	Machine 1; Paloona Power Station	Major Outage - CA8 & Major Works.	17/06/2013 7:31	8/08/2014 17:00
100000131	PO2	Machine 2; Poatina Power Station	Major Outage -CA8 & T/F Upgrade	22/07/2013 10:48	11/09/2013 15:51
100000111	TA1	Machine 1; Tarraleah Power Station	Major Outage - CA4 & Refurbs.	6/08/2013 8:30	9/12/2013 5:30
100000134	PO5	Machine 5; Poatina Power Station	Major Outage - CA4 & T/F Upgrade	16/09/2013 7:30	24/10/2013 14:30
100000039	BG1	Machine 1; Butlers Gorge Power Station	Major Outage - CA4	21/10/2013 7:00	1/11/2013 11:00
100000155	RO1	Machine 1; Rowallan Power Station	Major Outage	25/11/2013 7:00	14/02/2014 14:00
100000146	RE1	Machine 1; Repulse Power Station	Major outage - CA4	14/01/2014 7:00	23/01/2014 16:00
100000070	WY	Wayatinah Power Station	Intake Gate Replacement	18/01/2014 7:00	10/03/2014 16:00
100000059	DG1	Machine 1; Devil's Gate Power Staiton	Major Outage - CA4	18/01/2014 11:00	29/01/2014 16:34
100000104	TR2	Machine 2; Trevallyn Power Station	Major Outage	3/02/2014 7:00	29/04/2014 15:00
100000089	LY3	Machine 3; Liapootah Power Station	Major Outage	10/02/2014 6:40	28/02/2014 15:40
100000109	TA2	Machine 2; Tarraleah Power Station	Major Outage - CA4 & Shaft Replacement	17/02/2014 6:30	26/05/2014 6:30
100000113	MA1	Machine 1; Mackintosh/Murchison Pwr Stn	Major Outage excitation upgrade	17/02/2014 7:30	4/04/2014 15:00
1000001185	CA1	Machine 1; Catagunya Power Station	CA1, commissioning, Gov and AVR tests	28/04/2014 9:00	6/05/2014 13:00
100000105	TR1	Machine 1; Trevallyn Power Station	Major Outage - CA4	5/05/2014 7:00	21/05/2014 16:09
100000108	TA5	Machine 5; Tarraleah Power Station	Major Outage - Shaft Replacement	7/07/2014 7:30	15/10/2014 7:30
100000137	PO	Poatina Power Station	HTV Refurbishment	16/08/2014 10:00	12/09/2014 16:30
1000002224	PO3	Machine 3; Poatina Power Station	PO3 Major Outage 8 Yearly	18/08/2014 7:30	9/01/2015 14:00
1000002269	LE	Lake Echo Power Station	LE Runner Repairs & Pinch re-set	29/08/2014 9:00	5/11/2014 8:00
1000000119	MB1	Machine 1; Meadowbank Power Station	Major Outage 8 Yearly and Refurb.	15/09/2014 7:30	11/11/2015 16:30
1000002488	GO1	Machine 1; Gordon Power Station	GO1 Major Outage 8-Yearly	5/10/2014 8:00	13/11/2014 15:00
1000002489	GO2	Machine 2; Gordon Power Station	GO2 Major Outage 8-Yearly	5/10/2014 8:00	6/11/2014 16:00
1000000074	GO3	Machine 3; Gordon Power Station	GO3 Major Outage 8 Yearly	5/10/2014 8:00	19/12/2014 16:00
1000000072	GO	Gordon Power Station	Intake Gate Major Outage 4 Yearly	5/10/2014 14:00	3/11/2014 16:30
1000002263	AL	Arthur's Lake Pump Station	Maintenance Outage	10/11/2014 7:00	11/11/2014 15:00
100000147	RC1	Machine 1; Reece Power Station	RC1 Major outage 4 Yearly	17/11/2014 8:00	15/01/2015 17:00
1000000062	FS1	Machine 1; Fisher Power Station	Major Machine Refurbishment	1/12/2014 8:00	31/07/2015 16:30
1000000093	TU4	Machine 4; Tungatinah Power Station	HTV Refurbishment (TU4)	1/12/2014 8:00	27/04/2015 16:00
1000000091	TU5	Machine 5; Tungatinah Power Station	HTV Refurb	1/12/2014 8:00	29/04/2015 16:00
1000000049	CA2	Machine 2; Catagunya Power Station	CA2 - Major Outage 8 Yearly	5/01/2015 7:00	8/02/2015 16:00
1000000054	CE1	Machine 1; Cethana Power Station	Major Machine Refurbishment	2/02/2015 8:00	5/11/2015 12:00
1000000065	WY1	Machine 1; Wayatinah Power Station	WY1 Major Outage 8 Yearly	9/02/2015 7:00	11/03/2015 16:00
1000002201	LM1	Machine 1; Lemonthyme Power Station	Major outage 8 yrly & runner repairs	9/02/2015 7:30	31/03/2015 15:30
1000000092	LY2	Machine 2; Liapootah Power Station	LY2 Major Outage 4 Yearly	2/03/2015 7:00	2/04/2015 9:00
1000002568	RC2	Machine 2; Reece Power Station	RC2 excitation upgrade	2/03/2015 7:00	20/03/2015 16:00
1000002998	LY2	Machine 2; Liapootah Power Station	LY 2 Runner Weld Repairs	9/04/2015 8:00	27/04/2015 16:00
1000003123	AL	Arthur's Lake Pump Station	Maintenance Outage & Splitter Insp	27/05/2015 8:30	29/05/2015 15:00
100000143	PO4	Machine 4; Poatina Power Station	PO4 Major Outage 8 Yearly	20/07/2015 7:30	29/08/2015 16:30
1000000548	TA	Tarraleah Power Station	Replace 1-3 HTV's and canal works	7/09/2015 7:00	23/09/2015 16:00
1000000734	TA1	Machine 1; Tarraleah Power Station	#1 HTV replacement	7/09/2015 7:00	8/12/2015 16:00
1000000579	TA2	Machine 2; Tarraleah Power Station	#2 Hill Top Valves Replacement	7/09/2015 7:00	8/12/2015 6:59

100000732	TA3	Machine 3; Tarraleah Power Station	#3 HTV Replacement	7/09/2015 7:00	11/12/2015 6:59
100000892	BG1	Machine 1; Butlers Gorge Power Station	Mods to guide vanes & rewedge	8/09/2015 8:00	23/12/2015 16:00
100001664	PO	Poatina Power Station	PO Busbar CA2	14/10/2015 8:30	19/10/2015 16:00
100000523	PO6	Machine 6; Poatina Power Station	PO6 Major Outage 8 Yearly	17/10/2015 7:00	4/12/2015 17:30
100000079	TU4	Machine 4; Tungatinah Power Station	TU4 Major Machine Refurb & 8 Yearly	2/11/2015 8:00	4/07/2016 17:00
100000492	AN1	Machine 1; Anthony/Tribute Power Station	AN1 Major Outage 4 Yearly	14/11/2015 7:00	11/12/2015 16:00
100004041	AL1	Pumpset 1; Arthur's Lake Pump Station	Pump Outage	14/11/2015 14:30	16/11/2015 10:00
100000670	LY1	Machine 1; Liapootah Power Station	LY1 Major Outage 4 Yrly - reduced scope	18/01/2016 6:40	29/01/2016 15:40
100000682	WY3	Machine 3; Wayatinah Power Station	WY3 Major Outage 8-Yearly	1/02/2016 7:00	2/03/2016 15:00
100002862	TU5	Machine 5; Tungatinah Power Station	TU5 4Yrly Outage	1/02/2016 7:30	26/02/2016 16:00
100000773	JB1	Machine 1; John Butters Power Station	JB 8-Yearly	7/02/2016 7:00	11/03/2016 13:00
100004005	AL	Arthur's Lake Pump Station	AL Maintenance Outage & Intake dive work	8/02/2016 8:00	20/02/2016 15:00
100000680	WL	Wilmot Power Station	WL Major Outage 4-Yearly	8/02/2016 8:00	11/03/2016 16:00
100004043	TA5	Machine 5; Tarraleah Power Station	Runner replacement	22/02/2016 7:00	19/03/2016 16:00
100000171	TU1	Machine 1; Tungatinah Power Station	Major outage 4 yearly	29/02/2016 6:30	8/04/2016 15:00
100000869	LY3	Machine 3; Liapootah Power Station	4-Yearly and runner Inspection	29/02/2016 7:00	24/03/2016 16:00